



## EXECUTIVE SUMMARY OF BID EVALUATION REPORT

[Issued in terms of section 7(1)(i) of the Public Procurement Act, 2015]

### Procurement of Pump-sets c/w Shaft Couplings and Base Frames for Ondangwa SE Pump Station Procurement Reference No: G/OIB-002/2026

Namibia Water Corporation Ltd.  
Private Bag 13389  
176 Iscor Street, Aigams Building  
Windhoek

Email: [bids@namwater.com.na](mailto:bids@namwater.com.na)

Website: [www.namwater.com.na](http://www.namwater.com.na)



AN

## Executive Summary of Bid Evaluation Report

**Project Title: Procurement of Pump-sets c/w Shaft Couplings and Base Frames for Ondangwa SE Pump Station Reference number of procurement: G/OIB-002/2026**

1. **Scope of Contract:** Procurement of Pump-sets c/w Shaft Couplings and Base Frames for Ondangwa SE Pump Station
2. **Procurement method used:** Open International Bidding, in line with Section 30 of the Public Procurement Act, Act 15 of 2015 as amended.
3. **Date of Invitation of Bids:** 05 October 2025
4. **Closing date for submission of bids:** 25 November 2025
5. **Date and place of opening of bids:** 25 November 2025  
Namibia Water Corporation Ltd, 176 Iscor Street,  
Aigams Building, Windhoek
6. **Number of bids received by closing date:** 3 bids.
7. **Responsiveness of bids:**

Name of Applicant	Offered Bid Price (Excl. VAT)	Responsive or not responsive (Yes/ No)	Reasons why bid is not responsive
KSB Pumps and Valves Namibia Pty Ltd	4,814,478.93	Yes	<ul style="list-style-type: none"> <li>• Bidder not disqualified</li> </ul>
Conserv Engineering Services CC	7,350,000.00	No	<p><b><u>Technical Non-compliance regarding pump components and materials of construction</u></b></p> <ul style="list-style-type: none"> <li>• Pumps bearing lubrication not indicated.</li> <li>• Pump impeller balancing standard not indicated.</li> </ul>
Pumping Solutions CC	7,378,954.20	No	<p><b><u>Technical Non-compliance regarding pump performance</u></b></p> <ul style="list-style-type: none"> <li>• The Pump not confirmed to be suitable for continuous operation between 25Hz and 50 Hz.</li> <li>• Pump rate for 1,450 rpm.</li> <li>• Pump efficiency is 84.1%.</li> </ul>

Conserv Engineering Services CC, and Pumping Solutions CC was not considered for further evaluation.

AN

8. Price comparison for bids that are substantially responsive:

Name	A. Price at Bid Opening N\$	B. Bid Price after corrections	C. price after Adjustments N\$	D. Price after Margin of Preference [If applicable]	Rank
KSB Pumps and Valves Namibia Pty Ltd	4,814,478.93	None	N/A	N/A	1

9. Best Evaluated bid

KSB Pumps and Valves Namibia Pty Ltd for the Bid Offer amount of N\$ **4,814,478.93** (excl. VAT).

rw