



**AWARD OF PROCUREMENT CONTRACT**

**NOTICE UNDER SECTION (8) OF THE PUBLIC PROCUREMENT ACT NO. 15 OF  
2015**

This is to notify that, following the bidding exercise carried out by the Namibia Water Corporation Ltd title **Supply and delivery of Electromagnetic flow meters for NamWater Pump Stations. (Procurement Reference No. G/ONB/NW-005/2022)**, the contract has been awarded **Ecotech (Pty) Ltd** for a sum of **N\$ 2,164,302.47 (Exclusive VAT)**.





## **EXECUTIVE SUMMARY OF BID EVALUATION REPORT**

[Issued in terms of section 7(1)(i) of the Public Procurement Act, 2015]

### **Supply and delivery of Electromagnetic flow meters for NamWater Pump Stations.**

**Reference No: G/ONB/NW – 005/2022**

**Namibia Water Corporation Ltd.  
Private Bag 13389  
176 Iscor Street, Aigams Building  
Windhoek**

**Email: [bids@namwater.com.na](mailto:bids@namwater.com.na)**

**Website: [www.namwater.com.na](http://www.namwater.com.na)**

## Executive Summary of Bid Evaluation Report

**Project Title: Supply and delivery of Electromagnetic flow meters for NamWater Pump Stations.**

**Reference number of procurement: G/ONB/NW – 005/2022**

1. **Scope of Contract:** Supply and delivery of Electromagnetic flow meters for NamWater Pump Stations.
2. **Procurement method used:** Open National Bidding (ONB)
3. **Date of Invitation of Bids:** 06 August 2021
4. **Closing date for submission of bids:** 30 August 2021
5. **Date and place of opening of bids:** 30 August 2021, Namibia Water Corporation Ltd, 176 Iscor Street, Aigams Building, Windhoek
6. **Number of bids received by closing date:** 3 bids
7. Responsiveness of bids:

Name of Bidder	Pricing at Bid Opening N\$	Adjusted Offers N\$	Responsive or not responsive (Yes/ No)	Technical Criteria Specified	Reasons why bid is not responsive
<b>Dynamic Power Solutions cc</b>	N\$ 1,753,696.08	N\$ 1,950,269.72	No	<ul style="list-style-type: none"> <li>• The bidder shall furnish documentary evidence to demonstrate that the offered goods meet the required usage.</li> </ul>	<ul style="list-style-type: none"> <li>• Insufficient supporting literature/data sheet submitted hence validation of the following technical specifications cannot be confirmed;                             <ul style="list-style-type: none"> <li>○ Maximum velocity range</li> <li>○ Minimum velocity range</li> <li>○ 4 – 20 mA output available</li> <li>○ Accuracy</li> <li>○ CE Certified</li> </ul> </li> </ul>

				<ul style="list-style-type: none"> <li>• 2 x 1200 mm, PN 6 meters, shall be able to function without the normal inlet &amp; outlet run's, the inlet and outlet run's are zero</li> <li>• The cost for verification per meter shall be submitted with the offer. The complete cost should be submitted, verification cost per meter, traveling cost per km, S&amp;T rates, verification certificate cost, technician time for travel, and technician time for the verification</li> </ul>	<ul style="list-style-type: none"> <li>○ Pulse output for external counter</li> <li>○ Forward, reverse &amp; sum flow totalizers</li> <li>• Zero D inlet and D outlet flow meter data sheet not attached, thus technical specifications compliance status cannot be confirmed.</li> <li>• The product does not offer on board verification and the cost of verification was not submitted as specified in the bidding document.</li> </ul>
<b>Central Technical Supplies Pty Ltd Opt 1</b>	N\$ 1,758,445.84	N\$ 1,945,957.46	No	<ul style="list-style-type: none"> <li>• 2 x 1200 mm, PN 6 meters, shall be able to function without the normal inlet &amp; outlet runs, the inlet and outlet runs are zero.</li> </ul>	<ul style="list-style-type: none"> <li>• Zero D inlet and D outlet flow meter data sheet not attached, thus technical specifications compliance status cannot be confirmed.</li> </ul>
<b>Central Technical Supplies Pty Ltd Opt 2</b>	N\$ 1,918,442.95	N\$ 2,116,733.35	No	<ul style="list-style-type: none"> <li>• 2 x 1200 mm, PN 6 meters, shall be able to function without the normal inlet &amp; outlet runs, the inlet and outlet runs are zero.</li> </ul>	<ul style="list-style-type: none"> <li>• Zero D inlet and D outlet flow meter data sheet not attached, thus technical specifications compliance status cannot be confirmed.</li> </ul>

<b>Ecotech Pty Ltd</b>	N\$ 1,940,544.27	N\$ 2,164,302.47	Yes		
------------------------	---------------------	---------------------	-----	--	--

Price at evaluation of bid was adjusted as per above table to reflect augmented meter's quantities.

Dynamic Power Solutions cc and Central Technical Supplies Pty Ltd offers are disqualified for further evaluation due to technical non-compliance as illustrated above.

8. Price comparison for bids that are substantially responsive:

Name	A. Price at Bid Opening N\$	B. Bid Price after corrections	C. price after Adjustments N\$	D. Price after Margin of Preference [if applicable]	Rank
<b>Ecotech Pty Ltd</b>	N\$ 1,940,544.27	N/A	N\$ 2,164,302.47	N/A	1

9. Best Evaluated Bid:

TENDERER	TOTAL AMOUNT (EXCL. VAT)	DELIVERY PERIOD	RANK
Ecotech (Pty) Ltd.	<b>2,164,302.47</b>	6 - 12 weeks	1

